




施工令116条の2の検討											
				排煙		換気		採光			
	ダイニング・リビング・キッチン			必要量	39.50×1/50=0.79	必要量	39.50×1/20=1.98	必要量	39.50×1/7=5.64		
				有効量	$\frac{1}{AW} + \frac{2}{AW} + \frac{3}{AW} + \frac{4}{AW} \times 2 + \frac{5}{AW}$	有効量	$\frac{1}{AW} + \frac{2}{AW} + \frac{3}{AW} + \frac{4}{AW} \times 2 + \frac{5}{AW}$	有効量	$\frac{1}{AW} + \frac{2}{AW} + \frac{3}{AW} + \frac{4}{AW} \times 2 + \frac{5}{AW}$		
					2.56×0.4÷2=0.51		2.56×2.0÷2=2.56		2.56×2.0=5.12		
					1.65×0.4÷2=0.33		1.65×2.0÷2=1.65		1.65×2.0=3.30		
					2.56×0.4÷2=0.51		2.56×1.1÷2=1.41		2.56×1.1=2.82		
					(1.65×0.4÷2)×2=0.66		(1.65×1.1÷2)×2=1.82		(1.65×1.1)×2=3.63		
					0.74×0.4÷2=0.15		0.74×0.7÷2=0.26		0.74×0.7=0.52		
					0.51+0.33+0.51+0.66+0.15=2.16 OK		2.56+1.65+1.41+1.82+0.26=7.70 OK		(5.12+3.30+2.82+3.63+0.52)×3=46.17 OK		
	個室1・2・3・5			必要量	9.94×1/50=0.20	必要量	9.94×1/20=0.50	必要量	9.94×1/7=1.42		
				有効量	$\frac{4}{AW}$	有効量	$\frac{4}{AW}$	有効量	$\frac{4}{AW}$		
					1.65×0.4÷2=0.33 OK		1.65×1.1÷2=0.91 OK		1.65×1.1=1.82		
									1.82×3=5.46 OK		